

HISTOGRAPHIC ANALYSIS OF INFRARED THERMOGRAMS IN THE FIELD OF THERMAL ENGINEERING

Imre BENKŐ

Department for Energetics
Technical University of Budapest
H-1521 Budapest, Hungary

Received: Febr. 11, 1994

Abstract

Computerized evaluation of infrared images opens new vistas for infrared thermogrammetry (IR-TGM). While it extends our earlier knowledge regarding temperature field analysis, it requires deeper understanding of relations of thermal phenomena and also more intuitive thermotechnical skills for image processing. Examples from diverse areas, e.g. energy saving, thermal defectometry, electrotechnics are quoted and practical applications of IR-TGM in thermal physics of buildings are discussed. The thermal phenomena themselves are illustrated by IR thermograms, while temperature distributions are analysed by histograms.

Keywords: infrared thermogrammetry, energy saving, thermal defectometry.

1. Introduction

There are several approaches to and methods for development of digital infrared (IR) images [1],[5],[6]. It can be stated as a rule that evaluation strategy and method are advisably adapted to the examined phenomenon. This approach generally requires adequate thermal engineering practice and technical intuitiveness [2],[3],[4],[7].

2. Generalities

In analysing and disclosing various types of temperature fields, the following general methods may be attempted, whose applicability and convenience have to be decided for the actual case:

- proper definition of the tested temperature range, and within it, selection of number and width of isobands;
- determination of temperature prevailing in some points of the examined surface at the spiderlines centre (e.g. SPOT = 48.1 °C in Fig. 1);

- comparison of temperature distributions along horizontal and vertical lines by means of profile thermograms (see the bottom and the right side of *Fig. 1*);
- determination of the temperature distribution and of the mean temperature in selected minor areas of the surface examined (*Fig. 2* and *Table 1*);
- description of the temperature distribution by methods of mathematical statistics (*Fig. 3* and *Table 1*).






Fig. 1. The two profile thermograms on the bottom and on the right of the IR thermogram show the temperature distribution across the ribs of a radiator

3. Analysis of Temperature Distribution by Histogrammic Processing

Histogrammic processing is the usual mode of processing experimentally and otherwise obtained sets of data, but it may be regarded as an efficient way for describing temperature fields, too. Thereby there is still little experience available for such applications and for the proper evaluation of all histogram characteristics.

In histograms which represent temperature fields of digital IR images, pixel numbers with the given temperature are plotted against temperatures occurring within the fields (e.g. *Fig. 3*). Temperatures occurring in the selected area may be displayed both graphically and digitally, and the obtained data lend themselves for further computations. In our practice



satisfactory results were obtained when the temperature varied by tenths of degrees within the range.

Among essential values characteristic of the histograms, the following are pointed out: the highest (MAX), the lowest (MIN) and the average (AVG) temperature in the defined area; median (MED), standard deviation (Sdev) and skewness (SKEW) (see *Table 1*); number of pixels in the examined area (Ncal) and the maximum value on the ordinate of the histogram (Fmax) (e.g. *Fig. 2*). This paper presents several practical applications of IR image analysis in the field of thermal engineering.

4. Thermal Engineering Applications

For the calculation of heat loss of a surface, in steady-state conditions we have to know the wall temperature with appropriate accuracy. Connection between the average wall temperature (t_{avg}) and heat loss (\dot{Q}) is given by the following equation:

$$\dot{Q} = \sum_{i=1}^n A_i \alpha_i (t_{avg} - t_{env}). \quad (1)$$

Here A_i is a selected minor area ($i = 1 \dots n$) of the measured surface where α_i , the coefficient of heat transfer and emissivities are constant, t_{env} is the temperature of environment. So the values of temperature distribution in the selected area (*Table 1*) are very important for the determination of heat loss and other practical calculations.

4.1 Checking Radiator Operation

Operation of an aluminium radiator may be checked by means of infrared images (*Fig. 1*). Here isotherms and temperature distribution diagrams below and right of the image show that hot water supply of about six radiator ribs in the middle is less sufficient than that of the others, due to the poor internal flow conditions. Consequently, lower heat output occurs. The histographic representation of *Fig. 1* can be seen in *Figs. 2* and *3*. Data of histogram in *Fig. 3* obtained by computerized analysis are presented in *Table 1*.

4.2 Wall and Floor Heating

Determination of heat transfer by panels with internal heating (*Figs. 4* and *5*) at a due accuracy requires the knowledge of the mean wall temper-

Table 1
Collected data of histograms referred to

Topic	No. of histogram	No. of ref.fig.	Values of temperature distribution, °C					
			Characteristics of the histogram					
			MAX/MIN	AVG	MED	Sdev	SKEW	
1. Radiator	24-11	3.	47.1/37.2	43.5	43.7	1.7	2.0	
2. Wall heating coil	33-21	7.	53.1/23.5	38.2	38.5	4.8	5.5	
3. Insulation	PR-19	10.	21.3/ 7.3	9.9	9.8	1.1	1.8	
4.1 Below the windows	46-26	12.	16.1/12.7	13.8	13.7	0.5	0.6	
4.2 Between the windows	46-28	16.	14.8/12.2	13.3	13.2	0.4	0.4	
4.3 Around a window	46-28	16.	15.2/12.4	13.8	13.8	0.5	0.6	
5.1 Turbine insulation	33-13	22.	157 /11.7	56.0	49.7	23.4	29.6	
5.2 Turbine piping	33-13	22.	222 /35.5	76.7	75.2	22.0	34.4	




Fig. 4. IR thermogram and profile thermograms of a wall section heated by an internal pipe coil

ature (*Eq. 1*). The obtained thermogram and histograms (*Figs. 6 and 7*) assist reliable thermal sizing. One horizontal (a) and vertical (b) profile thermogram set across the wall section, which is heated by an internal pipe coil, are shown in *Fig. 5*, according to *Fig. 4*. The data of histogram: MAX: 53.1, MIN: 23.5, AVG: 38.2 (See *Table 1*).




Fig. 5. Horizontal (a) and vertical (b) profile thermograms across a wall section heated by an internal pipe coil (See Fig. 4)




Fig. 6. Histogram of Fig. 4 in a selected minor area

4.3 Insulation Defects of a District Heating Line

Infrared pictures (Fig. 8) taken from heating pipelines hint at possible causes of heat losses. Typical insulation defects of heating pipelines are presented (Fig. 9). Histogram data: MAX: 21.3, MIN: 7.3, AVG: 9.9 at -1°C environmental temperature (Fig. 10 and Table 1).




Fig. 7. Histogram of a wall heating coil (See Fig. 6)




Fig. 8. IR thermogram of insulation defects of a district heating line




Fig. 11. Histogram of a selected minor area below the windows of a prefabricated panel building

4.4 Checking a Building Envelope

Insulation quality control of the prefabricated panel buildings is an important practical task. The spots of thermal bridges may be pointed out in IR-images (Figs. 11 and 13). For calculating the local heat losses the different areas of the building envelope can be analysed. IR thermogram and histogram below the windows are presented in Figs. 11 and 12.

Histograms of a selected area between the windows in Fig. 11 can be seen in Figs. 13 and 15. A special relief thermogram of the same area Fig. 13 is presented in Fig. 14. This shows the spots of the thermal bridges. For the comparison of different areas of the building envelope in Fig. 15 the histogram around a window is presented and in Fig. 16 as comparative results. The data of the referred IR histograms are collected in Table 1.

4.5 Halogen Lamp

Internal and superficial temperature distribution of a TCF 250 6A-type high pressure sodium-vapour lamp manufactured by Tungsram has been tested (Figs. 17 and 19), helping to determine thermal fatigue versus frequency, hence expected service life of the sodium vapour lamp. One horizontal (a) and one vertical (b) temperature curve across the sodium vapour




Fig. 12. Histogram of a building envelope (below the windows) (See Fig. 11)

tube in the lamp can be seen in Fig. 18 in the period of maximum thermal wave (Fig. 17).

4.6 Efficiency of Thermal Insulation of Steam Turbines

Comparative analysis has been performed between thermal insulations of two turbines of the same type and service condition (Fig. 20). The results may also help in repairing thermal insulation. Data of histogram of LIMPET (British made) insulation: MAX: 197, MIN: 30.5, AVG: 75.4, and those of the Hungarian insulation: MAX: 157, MIN: 11.7, AVG: 56. The selected areas of the examined two parts of the turbines (insulation and piping) can be seen in Fig. 21. For comparison the histograms of areas on the insulation ($\epsilon = 0.9$) and piping ($\epsilon = 0.4$) are presented in Fig. 22.




Fig. 13. Histogram of a selected area between the windows of a panel building




Fig. 14. Relief thermogram of Fig. 13 shows the temperature distribution on the wall




Fig. 15. Histogram of an area around the window in Fig. 13




Fig. 16. Comparison of the histograms of a building envelope between and around the windows (See Fig. 13 and 15)




Fig. 17. IR thermogram of a sodium vapour tube in the lamp and profilethermograms across the tube in the period of maximum thermal wave




Fig. 18. Horizontal (a) and vertical (b) profile thermograms of Fig. 17 across a sodium vapour tube in the lamp




Fig. 19. Profile thermograms of Fig. 17 in the period of minimum thermal wave




Fig. 20. The examined section of the thermal insulation and piping of a steam turbine




Fig. 21. IR thermogram of Fig. 20 shows the selected areas for presentation of histograms on the piping and insulation of the turbine




Fig. 22. Comparison of the histograms of turbine insulation and piping (see Fig. 21)

5. Conclusion

Applications of quantitative IR-TGM by histograms in the representation of temperature fields give direct results in heat loss calculations, checking thermal insulation efficiency and defects as well as in observing thermal fatigue in electrical lamps.

References

1. BENKŐ, I.: Energy Related and other Applications of Thermogrammetric CAD (in Hungarian). *Mérés és Automatika*, Vol. 37, pp. 69–73 and 99–102, 1989.
2. BENKŐ, I.: Energy Conservation through Increased Emissivity in Furnaces. *Periodica Polytechnica, Ser. Mech. Eng.*, Vol. 35, pp. 235–245, 1991.
3. BENKŐ, I.: Applications of Infrared Thermography in Thermal Engineering. *QIRT 92 Eurotherm Series* Vol. 27, Paris, pp. 343–349, 1992.
4. BENKŐ, I.: Examination of Low Emissivity Coatings by Infrared Imagery. *Advanced Infrared Technology and Applications. (I.R.O.E. del C.N.R)* Florence, pp. 185–197, 1993.
5. BENKŐ, I.: Histogrammic Analysis of Infrared Thermograms in the Field of Engineering. *Workshop '93 on Advanced Infrared Technology and Applications. IROE-CNR, Capri*, 1993. p. 33.
6. BENKŐ, I.: Relationship between Thermal Engineering and Thermography. *Abstracts of 8th International Conference on Thermal Engineering and Thermography*. Budapest, 24 June, 1993. pp. 5–12.
7. BENKŐ, I.: Thermal Phenomena in Fatigue and Tensile Tests. *Abstracts of 8th International Conference on Thermal Engineering and Thermography*. Budapest, 24. June 1993. pp. 189–190.